

James A. Burkush
Chief of Department



City of Manchester
Fire Department
Fire Prevention Bureau

FIRE PREVENTION AND SAFETY COMPLIANCE STANDARD 2009-7

DATE: 4 February 2009

REGARDING: Fire Suppression Systems Non-Compliant Tags

DETAILS: (Description of specific orders to be followed)

Any engineered, pre-engineered, and self-service fire suppression system inspected and found to be in non-compliance, with its listing or manufacturers specifications, shall have a service tag attached indicating non-compliance.

- a. Non-compliance service tags shall be bright orange, have the words "Non-Compliance", and contain the firm name, Certificate of Registration number, date of inspection, the reason for non-compliance, and the initials and Certificate of Competency number of the person who conducted the inspection. The words "Non-Compliance" shall consist of block letters not less than one half inch in height, black in color
- b. The head of the fire department and the Fire Prevention Bureau shall be notified in writing, by the firm conducting the inspection, within 48 hours of the inspection identifying the fire suppression system in non-compliance and the reasons thereof
- c. The head of the fire department shall be notified in writing, by the firm conducting the service, within 48 hours of the completion of the work to bring the system into compliance

CODE OF ORDINANCES REFERENCE: **CITY OF MANCHESTER CODE OF ORDINANCES** SECTION 92.05, **INTERNATIONAL FIRE CODE 2006 ED** SECTION 104.1

James A. Burkush,
Chief of Department

Edward O'Reilly,
Chief of Fire Prevention