

James A. Burkush
Chief of Department



City of Manchester
Fire Department
Fire Prevention Bureau

FIRE PREVENTION AND SAFETY COMPLIANCE STANDARD 2011-3

DATE: 1 April 2011
REGARDING: OUTDOOR COOKING
DETAILS: (Description of specific orders to be followed)

CHARCOAL BURNERS AND OTHER OPEN FLAME COOKING SHALL NOT BE OPERATED ON COMBUSTIBLE BALCONIES OR WITHIN 10 FEET OF COMBUSTIBLE CONSTRUCTION IN THE CITY OF MANCHESTER, NH.

Exception:

1. One-and-two family dwellings

LP-GAS BURNERS HAVING AN LP-GAS CONTAINER WITH A WATER CAPACITY GREATER THAN 2.5 POUNDS (NOMINAL 1 POUND LP-GAS CAPACITY) SHALL NOT BE LOCATED OR STORED ON COMBUSTIBLE BALCONIES OR WITHIN 10 FEET OF COMBUSTIBLE CONSTRUCTION IN THE CITY OF MANCHESTER, NH.

Exception:

1. One-and-two family dwellings

CODE OF ORDINANCE REFERENCE: **CITY OF MANCHESTER CODE OF ORDINANCE** SECTION 92.05, **INTERNATIONAL FIRE CODE 2006 ED** SECTION 308.3.1 & 308.3.1.1

James A. Burkush,
Chief of Department

Edward O'Reilly,
Chief of Fire Prevention