

Daniel A. Goonan
Chief of Department



Andre R. Parent
Assistant Chief

City of Manchester
Fire Department
Fire Prevention Bureau
Peter J. Lennon, Fire Marshal

FIRE PREVENTION AND SAFETY COMPLIANCE STANDARD 2019-2

DATE:

REGARDING: Locking of Egress Doors

DETAILS: (Description of specific orders to be followed)

Surface mounted flush dead bolts and padlocks are **PROHIBITED**. At all times, Egress doors shall be accessible from the side from which egress is to be made, without the use of a key, special knowledge or effort.

CODE OF ORDINANCE REFERENCE: CITY OF MANCHESTER CODE OF ORDINANCE SECTION 92.05. INTERNATIONAL FIRE CODE 2006 EDITION SECTION 1008.1.8.4